

**REGIONAL WATER TESTING LAB, AMRITSAR**  
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.  
rwtlasr1@gmail.com

To,

Principal Sri Guru Teg Bahadur Public School  
Khankot, Distt. Amritsar


No.: RWTLASR/2627/00027 Dated : 08/04/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. S/D/149 Dated: 02/04/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 07/04/2026. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar

D/A : Test Report



Authorized Signatory  
For, Regional Water Testing Lab  
Amritsar



TC-13602

TEST REPORT						
Name & Address of Customer : Principal Sri Guru Teg Bahadur Public School Khankot, Distt. Amritsar			Customer Reference No.		No : S/D//149 Dated : 02/04/2026	
			Sample Submitted by		Mr.Arjun	
			Date of Sample Receipt		07/04/2026	
			Analysis Starting Date		07/04/2026	
			Analysis completion Date		08/04/2026	
Discipline : <b>Chemical Testing</b>			Group: <b>Water</b>			
ULR No.:	TC13602260000197F		Sample Type :		Water	
Test Report No.:	RWTLASR/2627/00027		Date of Issue :		08/04/2026	
Registration no.:	RWTLASR/REG2627/00042		Condition of Sample :		sealed	
Collection Point:	Private Submersible		Quantity/Type of Bottle:		1000 ml / Plastic Bottles	
Scheme/Source:	Not Mentioned(Not Mentioned)		Location/Depth :		(S/pump 400 ft) / NA	
Village :	Not Mentioned		Habitation :		Not Mentioned	
Block:	Not Mentioned		District :		Amritsar	
Latitude :	Not Mentioned		Longitude:		Not Mentioned	
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.48@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	268	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.50@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO <sub>3</sub> )	188	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO <sub>3</sub> )	196	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	40.08	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	23.32	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	23.99	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr. Pardeep kumar  
Quality Manager  
Authorized Signatory  
For, Regional Water Testing Lab  
Amritsar

..... End of the Test Report .....